




3 CONDENSATE PUMP INSTALLATION (CP-1)
SCALE, NONE









- 1. PROVIDE SADDLE SUPPORTS AND LEGS OR HANGERS FOR HEAT EXCHANGER. MOUNTING HEIGHT SHALL BE ADJUSTED TO FACILITATE GRAVITY RETURN OF STEAM CONDENSATE.
- 2. MAKE THE BYPASS THE SAME SIZE AS THE CONNECTIONS TO THE CONTROL VALVES.
- 3. CONTROL VALVES SHALL BE IN A 1 AND 3 SIZE ARRANGEMENT.






5 HEAT EXCHANGER SUPPORT SCALE, NONE




- 1. UNLESS OTHERWISE SHOWN ON THE DRAWINGS, SIZE THE VENT PIPE SO THAT STEAM IS NOT BLOWN OUT AT THE VENT PIPE ENTRANCE. UTILIZE THE CALCULATION METHOD CONTAINED IN ANSI B31.1. POWER PIPING CODE, APPENDIX II.
- 2. VENT PIPE SHALL TERMINATE 6' [1829mm] MIN. ABOVE FINISHED ROOF.
- 3. DISCHARGE OF DRAIN MUST BE DIRECTED AWAY FROM PLATFORMS OR OTHER AREAS WHICH PERSONNEL MAY OCCUPY.
- 4. DO NOT CONNECT ANY OTHER DRAIN TO THE DRIP PAN ELBOW DRAIN PIPE.

STEAM PRESSURE RELIEF VALVE SCALE: NONE



RENEW DATE: 6-30-13 Notes M. Nota W. OREGON & OBERT W.

Medford, Oregon 97504





DEPARTMENT OF VETERANS AFFAIRS

SOUTHERN OREGON **REHABILITATION CENTER & CLINICS**

8495 CRATER LAKE HIGHWAY WHITE CITY, OREGON

DRAWING TITLE: **MECHANICAL DETAILS**

MAI Project Number: 10-112 F: 541-779-4079 PO Box 490

PROJECT TITLE REPLACE NUTRITION & 5 FOOD SERVICES DRAWING NO .:

VA PROJECT NO.: 392<u>-338</u> **DWG.180F 21**